



WTA ARCHITECTS

100 S Jefferson Ave, Suite 601
Saginaw, Michigan 48607
989 752 8107 : p
989 573 0855 : f

WTAARCH.COM

ADDENDUM NO. 1

STATE OF MICHIGAN
DEPARTMENT OF TECHNOLOGY, MANAGEMENT AND BUDGET
DEPARTMENT OF NATURAL RESOURCES

NEW BUILDING FOR:
MACKINAC ISLAND STATE HARBOR
COMFORT STATION REPLACEMENT
MACKINAC ISLAND, MICHIGAN 49757

File No. 751/17146.TAP
Index No. 53250
Architect Project No. 2018060
June 24, 2022

The following clarifications, modifications and/or revisions to the above project shall be considered a part of the original drawings and specifications.

It shall be the responsibility of the contractor to notify their subcontractors and/or suppliers of the clarifications, modifications, and/or revisions included herein.

ARCHITECTURAL

Item A1: Refer to Specification Section 044313.16 Adhered Stone Masonry Veneer (not re-issued)

Delgado Stone is approved as an equal manufacturer.

Item A2: Refer to Specification Section 051200 Structural Steel Framing (not re-issued)

Delete all AISC related requirements.

Item A3: Refer to Specification Section 071616 Crystalline Waterproofing (not re-issued)

Clarification: Provide crystalline waterproofing at concrete foundation walls only. Concrete slab on grade, footings, and exterior concrete is not required to have crystalline waterproofing.

June 24, 2022

PAGE 2



MECHANICAL

Item M1: Refer to Specification Section 230593 Testing, Adjusting, and Balancing (not re-issued)

Integrity Test & Balance of Traverse City, MI, is approved as an acceptable test and balance contractor.

END OF ADDENDUM NO. 1