



**Michigan
Technological
University**

ADDENDUM # 1

PROJECT #32-23-01

**LOWER DANIELL HEIGHTS
BREEZEWAY ROOFS 2022**

August 8, 2022

Contractor shall list all addenda by number on the bid form to ensure conformity in the bid.

Drawings, Specifications and/or Proposals are herein amended, expanded and/or modified, as hereinafter described, and become a part of the Contract Documents with the same force and effect as if incorporated, herein, originally. Any contrary provisions contained, or referred to, in Drawings and/or Specifications, shall remain applicable unless overridden by this Addendum. Revised or contrary provisions herein shall not affect any other part of the Contract Documents and any deletions, additions, substitutions and/or revisions mentioned, shall include all labor, materials, methods, modifications, etc. required for complete performance of the work.

CONTRACT DOCUMENT MODIFICATIONS AND CLARIFICATIONS:

1. Drawing D101: Add Keynote #7, Remove existing roofing below the existing EPDM.
2. Drawing A101 and Drawing A201: Revise Keynote #1 on A101 and Keynote #2 on A201 to be 5/8" Plywood in lieu of 7/16".

End of Addendum